



ROC L-16 092461

FIRE EQUIPMENT SALES
AND SERVICE CORPORATION

ROC L-67 092462

3107 W. VIRGINIA AVE. ★ PHX, AZ 85008-1504 ★ (602)433-2484 ★ Fax (602)433-9626
2921 S. KISH AVE ★ YUMA, AZ 85365 ★ (928) 341-0025 ★ Fax (928) 341-0356
SHOW LOW ★ PINETOP ★ LAKESIDE ★ (928) 622-2292

10/29/2012

Jeff Akins
Blue Ridge High School Main
1200 W. Mountain Bl.
Lake Side, Az. 85929

Phone: 928-369-3945
E-Mail: jakins@brusdk12.az.us
DNR#: SLM176

RE: Fire alarm repairs per system report dated 7/30/2012. TECHNOLOGY OFFICE pg. 1

American Fire Equipment Sales & Service would like to present you with the following proposal for the above referenced facility.

Deficiencies Noted

- ▶ Fire alarm system is not remotely monitored. Manual pull 2-43, 2-31 east & west hallway, 2-39 are reporting to panel incorrectly. Smoke detector 2-41 is reporting to panel incorrectly.
- ▶ Smoke detectors 2-38 and 1-4 are reporting to fire alarm panel incorrectly. Pull station 2-34 is reporting incorrectly
- ▶ New gym north hall outside boys locker room horn strobe not functioning.
- ▶ Media center storage rm. Has 2 old heat detectors that are not siemens addressable heats & cause a short on the data loop when tested.

Scope of Work

- ▶ Reprogram pull stations 2-31 east and west, 2-43, 2-39 and 2-34 to report to panel correctly.
- ▶ Reprogram Smoke detectors 2-41, 2-38 and 1-4 to report to panel correctly.
- ▶ Replace inoperable horn/strobe that is not functioning in new gym north hall.
- ▶ Replace Two (2) non Siemens addressable heats that are causing a short with Two (2) Siemens HP-11 smoke detectors.

Cost Summary

American Fire Equipment is pleased to provide and complete the above scope of work for the sum of:

Total Labor	\$1,360.00
Total Materials	\$590.00
Sub Total	\$1,950.00
Tax	\$54.87
Total Proposal	<u>\$2,004.87</u>